



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* Hampshire House Apt

*Date:* 8/12/25

*Address:* 195 Mt. Lebanon Blvd.  
Pittsburgh, PA 15228

*Time:* 9:15 AM

*Method:* Grab

**Sample Final Analysis**

*Matrix:* Recreational Water

*Date:* 8/15/25

*Source Type:* Pool

*Time:* 9:00 AM

*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25 11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25 5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25 9:15 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25 9:15 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 9:15 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Hampshire House Apt*

*Date: 8/12/25*

*Address: 195 Mt. Lebanon Blvd.*  
*Pittsburgh, PA 15228*

*Time: 9:15 AM*

*Method: Grab*

*Matrix: Recreational Water*

**Sample Final Analysis**

*Date: 8/15/25*

*Time: 9:00 AM*

*Source Type: Pool*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	8/13/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:00 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25	9:15 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/12/25	9:15 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	9:15 AM	CW	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor