1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

			Sample Collection	
Facility Name:	Extended Stay		Date:	5/27/25
			Time:	9:42 AM
Address:	136 Emeryville Dr.		Method:	Grab
	Cranberry Twp., PA 16066			
			Sample Final Analysis	
Matrix:	Recreational Water		Date:	5/30/25
			Time:	9:00 AM
Source Type:	Pool		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	9:42 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:42 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:42 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

Facility Name:	*Extended Stay*
Address:	*136 Emeryville Dr.*
	Cranberry Twp., PA 16066
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*5/27/25*
Time:	9:42 AM
Method:	*Grab*

Sample Final Analysis

Date:	*5/30/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	5/27/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/27/25	9:42 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:42 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:42 AM	ZR	Visual

Sample comments

_____
Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)