



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2724**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Traditions of America Southpointe*

*Date: 8/26/25*

*Address: 105 Liberty Blvd.*  
*Cannonsburg, PA 15317*

*Time: 11:36 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 8/28/25*

*Source Type: Spa*

*Time: 9:00 AM*

*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G

Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
------------------	----------	----------	---------	----------	----	----------

Standard plate count:	570/ml	200/ml	8/26/25	5:30 PM	AS	SM 9215B
-----------------------	--------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/27/25	12:10 PM	PS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/26/25	11:36 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/26/25	11:36 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	11:36 AM	AF	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor