



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2136

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Wynnwood @ Freedom Road*

Address: *501 Cranberry Pointe Lane*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/18/25*
Time: *12:09 PM*
Method: *Grab*

Sample Final Analysis

Date: *8/21/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25 10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25 10:00 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	8/18/25 4:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/18/25 12:09 PM	ZR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	8/18/25 12:09 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25 12:09 PM	ZR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor