



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2164

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Eden Square

Date: 8/18/25

Address: 9000 Old Station Rd.
Cranberry, PA 16066

Time: 2:05 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/21/25

Source Type: Pool

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	4:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/18/25	2:05 PM	ZR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/18/25	2:05 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	2:05 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor