



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 453

Customer

Facility Name: *Fairfield Inn Butler*

Address: *200 Fairfield Ln
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/8/25*

Time: *3:40 PM*

Method: *Grab*

Sample Final Analysis

Date: *9/11/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/25 10:15 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/25 10:15 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/25 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	9/8/25 3:40 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	9/8/25 3:40 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/25 3:40 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor