



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2145

Customer

Facility Name: Crown Plaza
Address: 164 Fort Couch Rd.
Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/3/25
Time: 12:00 AM
Method: Grab

Sample Final Analysis

Date: 6/6/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25	9:24 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	9:24 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	9:24 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2145

Customer

Facility Name: *Crown Plaza*
Address: *164 Fort Couch Rd.*
Pittsburgh, PA 15241

Sample Collection

Date: *6/3/25*
Time: *12:00 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/6/25*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/3/25	9:24 AM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/3/25	9:24 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	9:24 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor