



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2224

**Customer**

Facility Name: *Gateway Heights*  
Address: *2249 Ramsey Road  
Monroeville, PA 15146*  
Matrix: *Recreational Water*  
Source Type: *Baby Pool*

**Sample Collection**

Date: *7/8/25*  
Time: *11:30 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/11/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB
Total coliforms:	10/100mls	2/100mls	7/9/25	9:00 AM	EB
Standard plate count:	5700/ml	200/ml	7/8/25	3:28 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	EH
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	EH
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	EH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2224

**Customer**

Facility Name: *Gateway Heights*  
Address: *2249 Ramsey Road  
Monroeville, PA 15146*  
Matrix: *Recreational Water*  
Source Type: *Baby Pool*

**Sample Collection**

Date: *7/8/25*  
Time: *11:30 AM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/11/25*  
Time: *9:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:00 AM	EB
Total coliforms:	10/100mls	2/100mls	7/9/25	9:00 AM	EB
Standard plate count:	5700/ml	200/ml	7/8/25	3:28 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/8/25	11:30 AM	EH
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/8/25	11:30 AM	EH
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	11:30 AM	EH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor