



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2392

**Customer**

Facility Name: Park Swim Club  
Address: College Park Dr.  
Monroeville, PA 15146  
Matrix: Recreational Water  
Source Type: Deep End

**Sample Collection**

Date: 5/29/25  
Time: 2:25 PM  
Method: Grab

**Sample Final Analysis**

Date: 5/31/25  
Time: 3:30 PM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB
Standard plate count:	200/ml	200/ml	5/29/25	4:40 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/29/25	2:25 PM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	2:25 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	2:25 PM	ZR

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E - 13

Lab# 2392

**Customer**

Facility Name: Park Swim Club  
Address: College Park Dr.  
Monroeville, PA 15146  
Matrix: Recreational Water  
Source Type: Deep End

**Sample Collection**

Date: 5/29/25  
Time: 2:25 PM  
Method: Grab

**Sample Final Analysis**

Date: 5/31/25  
Time: 3:30 PM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	5:00 PM	EB
Total coliforms:	0/100mls	2/100mls	5/29/25	5:00 PM	EB
Standard plate count:	200/ml	200/ml	5/29/25	4:40 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/29/25	2:25 PM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/29/25	2:25 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	5/29/25	2:25 PM	ZR

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor