



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2693

Customer

Facility Name: *Roaring Run*
Address: *194 Tannery Rd*
Champion, PA 15622

Sample Collection

Date: *8/25/25*
Time: *12:26 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *8/28/25*
Time: *9:00 AM*
Analyst: *AS*

Source Type: *Baby Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/25	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	10:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	5:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/25/25	12:26 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/25/25	12:26 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	12:26 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor