



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041
W-2

Lab# 078

Laboratory Analysis Report

Customer

Facility Name: Courtyard by Marriott
Address: 5100 Campbells Run Rd.
Pittsburgh, PA 15205

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 12/29/25
Time: 11:30 AM
Method: Grab

Sample Final Analysis

Date: 1/1/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/25	9:50 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/25	9:50 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/29/25	3:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/29/25	11:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/29/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/29/25	11:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor