



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2395

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Parkside Estates*

Address: *202 Ketchum Court*
Cannonsburg, PA 15317

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/1/25*

Time: *1:37 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/4/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	1:37 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	1:37 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	1:37 PM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2395

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Parkside Estates*

Address: *202 Ketchum Court*
Cannonsburg, PA 15317

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/1/25*

Time: *1:37 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/4/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	1:37 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	1:37 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	1:37 PM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor