



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-12

Lab# 2488

Customer

Facility Name: Shannopin C.C.
Address: 1 Windmere Rd.
Pittsburgh, PA 15202

Sample Collection

Date: 8/20/25
Time: 2:22 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/22/25
Time: 3:30 PM
Analyst: AS

Source Type: Splash Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	5:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	5:45 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/20/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/20/25	2:22 PM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/20/25	2:22 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/20/25	2:22 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor