



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 2572**

**Customer**

**Facility Name:** Westmoreland Farms

**Address:** Wheatland Circle  
Delmont, PA 15626

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 7/22/25

**Time:** 6:45 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25

**Time:** 10:00 AM

**Analyst:** 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	6:45 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	6:45 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	6:45 AM	EH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 2572**

**Customer**

**Facility Name:** Westmoreland Farms

**Address:** Wheatland Circle  
Delmont, PA 15626

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 7/22/25

**Time:** 6:45 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/25/25

**Time:** 10:00 AM

**Analyst:** 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	6:45 AM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	6:45 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	6:45 AM	EH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor