



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2748

Customer

Facility Name: Seven Oaks C.C.

Sample Collection

Date: 7/28/25

Time: 3:49 PM

Method: Grab

Address: 132 Lisbon Road
Beaver, PA 15009

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	3:49 PM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25	3:49 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	3:49 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2748

Customer

Facility Name: Seven Oaks C.C.

Sample Collection

Date: 7/28/25

Time: 3:49 PM

Method: Grab

Address: 132 Lisbon Road
Beaver, PA 15009

Sample Final Analysis

Date: 7/31/25

Time: 9:00 AM

Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/29/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	7:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	7/28/25	3:49 PM	AH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/28/25	3:49 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	3:49 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor