



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-3**

**Lab# 085**

**Customer**

Facility Name: Deer Lakes High School

Address: 163 East Union Rd.  
Russellton, PA 15076

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 11/4/25  
Time: 12:00 AM  
Method: Grab

**Sample Final Analysis**

Date: 11/7/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/5/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/5/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	11/4/25	4:32 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/4/25	11:32 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/4/25	11:32 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/4/25	11:32 AM	AMH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor