

## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-15

Lab ID No. 02-04041

Lab# 2475

Customer Facility Name: Seven Fields Borough

Address: 390 Castle Creek Drive

Seven Fields, PA 16046

Matrix: Recreational Water

Source Type: Pool Sample Collection

8/5/25 Date: Time: 10:15 AM Method: Grab

Sample Final Analysis

Date: 8/8/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	8/5/25	10:15 AM	ZR	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:15 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:15 AM	ZR	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## **Dream Pools and Spas** 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

N-15

Lab ID No. 02-04041

Lab# 2475

Customer Facility Name: Seven Fields Borough

Address: 390 Castle Creek Drive

Seven Fields, PA 16046

Matrix: Recreational Water

Source Type: Pool Sample Collection

8/5/25 Date: Time: 10:15 AM Method: Grab

Sample Final Analysis

Date: 8/8/25 Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	1:00 PM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	1:00 PM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	8/5/25	10:15 AM	ZR	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	10:15 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	10:15 AM	ZR	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor