



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2128**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Community Swim Club*

*Date: 7/16/25*

*Address: 106 Aqua Drive*  
*Pittsburgh, PA 15238*

*Time: 1:54 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 7/19/25*

*Source Type: Deep End*

*Time: 8:00 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/16/25	5:35 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	7/16/25	1:54 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/16/25	1:54 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	1:54 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2128**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Community Swim Club*

*Date: 7/16/25*

*Address: 106 Aqua Drive*  
*Pittsburgh, PA 15238*

*Time: 1:54 PM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 7/19/25*

*Source Type: Deep End*

*Time: 8:00 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>		<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	7/17/25	10:10 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/17/25	10:10 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/16/25	5:35 PM	SL	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>		<b>Analyst</b>	<b>Method</b>
pH:	7.4 SU	7.2 - 7.8 SU	7/16/25	1:54 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/16/25	1:54 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/16/25	1:54 PM	CW	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor