



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 287

Customer

Facility Name: Spring Hill Suites Mt Lebanon

Address: 611 Washington Rd.
Pittsburgh, PA 15228

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 11/26/25

Time: 10:13 AM

Method: Grab

Sample Final Analysis

Date: 11/28/25

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/26/25 3:40 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/26/25 3:40 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/26/25 3:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/26/25 10:13 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	11/26/25 10:13 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/26/25 10:13 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor