

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**S-12** 

Lab# 011

Customer	Sample Collection					
Facility Name:	Athletic Club Carnegie Library of Homestead			Date:	6/23/25	
A alalua a a	E40 E+ 40#	<i>l</i> -		Time:	11:00 AM	
Address:	510 East 10ti Munhall, PA			Method:	Grab	
	marinan, 170	10120	Sample Final Analysis			
Matrix:	Recreational Water			Date:	6/26/25	
Course Tuner	Dool			Time:	9:00 AM AS	
Source Type:	Pool			Analyst:	AS	)
Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Da	te/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	11:00 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:00 AM	DW	DPD

## Sample comments

Turbidity:

andre Smith

6/23/25

( When exceeding reporting limit pool or spa is unfit)

1 NTU

1 - 2 NTU

Andre Smith, Lead Supervisor

11:00 AM

DW

Visual



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

**S-12** 

Lab# 011

Customer	Sample Collection					
Facility Name:	Athletic Club Carnegie Library of Homestead			Date:	6/23/25	
A alalua a a	E40 E+ 40#	<i>l</i> -		Time:	11:00 AM	
Address:	510 East 10ti Munhall, PA			Method:	Grab	
	marinan, 170	10120	Sample Final Analysis			
Matrix:	Recreational Water			Date:	6/26/25	
Course Tuner	Dool			Time:	9:00 AM AS	
Source Type:	Pool			Analyst:	AS	)
Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	11:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	11:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	6:10 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Da	te/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/23/25	11:00 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/25	11:00 AM	DW	DPD

## Sample comments

Turbidity:

andre Smith

6/23/25

( When exceeding reporting limit pool or spa is unfit)

1 NTU

1 - 2 NTU

Andre Smith, Lead Supervisor

11:00 AM

DW

Visual