



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**

Lab ID No. 02-04041

**W-12**

**Lab# 324**

**Laboratory Analysis Report**

**Customer**

Facility Name: Verland Foundation  
Address: 212 Iris Rd.  
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/9/25  
Time: 11:30 AM  
Method: Grab

**Sample Final Analysis**


Date: 7/12/25  
Time: 8:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	11:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	11:30 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

  
Anare Smith, Lead Supervisor



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

W-12

Lab# 324

## Laboratory Analysis Report

### Customer

Facility Name: Verland Foundation  
Address: 212 Iris Rd.  
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 7/9/25  
Time: 11:30 AM  
Method: Grab

### Sample Final Analysis


Date: 7/12/25  
Time: 8:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	11:30 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	11:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	11:30 AM	VH	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

  
Anare Smith, Lead Supervisor