



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 300**

**Customer**

**Facility Name:** Trinity Middle School  
**Address:** 50 Scenic Dr.  
Washington, PA 15301

**Sample Collection**

**Date:** 11/24/25  
**Time:** 9:00 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 11/27/25  
**Time:** 10:00 AM  
**Analyst:** AS

**Source Type:** Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/24/25	9:00 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25	9:00 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	9:00 AM	GR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)