



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

Facility Name: Schenley
Address: 1 Overlook Dr.
Pittsburgh, PA 15213

Sample Collection

Date: 8/12/25
Time: 10:30 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25	10:30 AM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:30 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:30 AM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2471

Customer

Facility Name: Schenley
Address: 1 Overlook Dr.
Pittsburgh, PA 15213

Sample Collection

Date: 8/12/25
Time: 10:30 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	3:58 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/12/25	10:30 AM	WB	DPD
Chlorine:	1.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:30 AM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:30 AM	WB	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor