



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 266**

**Customer**

Facility Name: Residence Inn  
Address: 574 W. Generald Robinson St.  
Pittsburgh, PA 15212

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 1/6/26  
Time: 3:15 PM  
Method: Grab

**Sample Final Analysis**

Date: 1/9/26  
Time: 11:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/7/26	10:40 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/7/26	10:40 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/6/26	5:27 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/6/26	3:15 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/6/26	3:15 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/6/26	3:15 PM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)