

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2348

Customer

Facility Name: Meadowink Swim Club

Address: 4220 Bulltown Rd

Murrysville PA 15668

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/3/25
Time: 8:20 AM
Method: Grab

Sample Final Analysis

 Date:
 6/6/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 6/4/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 9:30 AM EΒ SM 9222B 6/4/25 Standard plate count: 0/ml 200/ml 6/3/25 3:25 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/3/25 | 8:20 AM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/3/25 | 8:20 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/3/25 | 8:20 AM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2348

Customer

Facility Name: Meadowink Swim Club

Address: 4220 Bulltown Rd

Murrysville PA 15668

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 6/3/25
Time: 8:20 AM
Method: Grab

Sample Final Analysis

 Date:
 6/6/25

 Time:
 9:30 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 6/4/25 9:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 9:30 AM EΒ SM 9222B 6/4/25 Standard plate count: 0/ml 200/ml 6/3/25 3:25 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/3/25 | 8:20 AM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/3/25 | 8:20 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/3/25 | 8:20 AM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor