



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:* Hampshire House Apt

*Date:* 5/28/25

*Address:* 195 Mt. Lebanon Blvd.  
*Pittsburgh, PA 15228*

*Time:* 9:10 AM

*Method:* Grab

**Sample Final Analysis**

*Matrix:* Recreational Water

*Date:* 5/31/25

*Source Type:* Pool

*Time:* 9:30 AM

*Analyst:* AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/29/25 11:30 AM     | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/29/25 11:30 AM     | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/28/25 6:25 PM      | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time       | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 5/28/25 9:10 AM | CW      | DPD    |
| Chlorine:      | 4.0 mg/l | 1.0 - 5.0 mg/l  | 5/28/25 9:10 AM | CW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/28/25 9:10 AM | CW      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2240**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Hampshire House Apt*

*Date: 5/28/25*

*Address: 195 Mt. Lebanon Blvd.*  
*Pittsburgh, PA 15228*

*Time: 9:10 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 5/31/25*

*Source Type: Pool*

*Time: 9:30 AM*

*Analyst: AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 5/29/25                     | 11:30 AM | EB             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 5/29/25                     | 11:30 AM | EB             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 5/28/25                     | 6:25 PM  | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.8 SU         | 7.2 - 7.8 SU           | 5/28/25          | 9:10 AM | CW             | DPD           |
| Chlorine:             | 4.0 mg/l       | 1.0 - 5.0 mg/l         | 5/28/25          | 9:10 AM | CW             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 5/28/25          | 9:10 AM | CW             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor