

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2005

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Accord -Avonworth

Address: 498 Camp Horne Road

Pittsburgh, PA 15237

Matrix: Recreational Water

**Results** 

Source Type: Shallow End

Sample Collection

Date: 6/3/25

Time: 11:06 AM

Method: Grab

Sample Final Analysis

**Incubation Date/Time** 

 Date:
 6/6/25

 Time:
 9:30 AM

 Analyst:
 AS

**Analyst** 

Method

 Escherichia Coli:
 Absent
 6/4/25
 11:30 AM
 EB
 SM 9222G

 Total coliforms:
 0/100mls
 2/100mls
 6/4/25
 11:30 AM
 EB
 SM 9222B

**Reporting limit** 

Standard plate count: 0/ml 200/ml 6/3/25 5:45 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25	11:06 AM	MM	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	11:06 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	11:06 AM	MM	Visual	

## Sample comments

**Accredited Analysis** 

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2005

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Accord -Avonworth

Address: 498 Camp Horne Road

Pittsburgh, PA 15237

Matrix: Recreational Water

**Results** 

Source Type: Shallow End

Sample Collection

Date: 6/3/25

Time: 11:06 AM

Method: Grab

Sample Final Analysis

**Incubation Date/Time** 

 Date:
 6/6/25

 Time:
 9:30 AM

 Analyst:
 AS

**Analyst** 

Method

 Escherichia Coli:
 Absent
 6/4/25
 11:30 AM
 EB
 SM 9222G

 Total coliforms:
 0/100mls
 2/100mls
 6/4/25
 11:30 AM
 EB
 SM 9222B

**Reporting limit** 

Standard plate count: 0/ml 200/ml 6/3/25 5:45 PM SL SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/3/25	11:06 AM	MM	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/3/25	11:06 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	11:06 AM	MM	Visual	

## Sample comments

**Accredited Analysis** 

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor