



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 158**

**Customer**

Facility Name: *Holiday Inn Express*  
  
Address: *181 Finley Rd.*  
*Belle Vernon, PA 15012*

**Sample Collection**

Date: *9/22/25*  
Time: *11:05 AM*  
Method: *Grab*

Matrix: *Recreational Water*  
  
Source Type: *Pool*

**Sample Final Analysis**

Date: *9/25/25*  
Time: *11:00 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	9/22/25	11:05 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/22/25	11:05 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	11:05 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor