



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

S-10

Laboratory Analysis Report Lab# 259

Customer

Facility Name: Providence Pointe

Address: 301 Kane Boulevard
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/7/25

Time: 12:44 PM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/8/25	12:00 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	12:44 PM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:44 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:44 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

S-10

Laboratory Analysis Report Lab# 259

Customer

Facility Name: Providence Pointe

Address: 301 Kane Boulevard
Pittsburgh, PA 15243

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/7/25

Time: 12:44 PM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:20 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:20 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/8/25	12:00 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	12:44 PM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:44 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:44 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor