



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2246

Customer

Facility Name: *Heritage Creek HOA*
Address: *115 Heritage Creek Drive*
Mars, PA 16046

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/9/25*
Time: *10:21 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/12/25*
Time: *8:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	10:21 AM	ZR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/9/25	10:21 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	10:21 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2246

Customer

Facility Name: *Heritage Creek HOA*
Address: *115 Heritage Creek Drive*
Mars, PA 16046

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/9/25*
Time: *10:21 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/12/25*
Time: *8:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/9/25	10:21 AM	ZR	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	7/9/25	10:21 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	10:21 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor