

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

C-11

Lab# 056

Customer

Facility Name: Club Pittsburgh

Address: 1139 Penn Ave.

Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/22/25

Time: 9:55 AM

Method: Grab

Sample Final Analysis

Date: Time: 7/25/25 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	9:55 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:55 AM	LM	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

C-11

Lab# 056

Customer

Facility Name: Club Pittsburgh

Address: 1139 Penn Ave.

Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/22/25

Time: 9:55 AM

Method: Grab

Sample Final Analysis

Date: Time: 7/25/25 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	11:00 AM	SL	SM 9222B
Standard plate count:	200/ml	200/ml	7/22/25	4:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/23/25	12:20 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/22/25	9:55 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/22/25	9:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	9:55 AM	LM	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor