



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 403**

**Customer**

**Facility Name:** Wilfred R.Cameron Wellness Center  
**Address:** 240 Wellness Way  
Washington, PA 15301

**Matrix:** Recreational Water  
**Source Type:** Therapy Pool

**Sample Collection**

**Date:** 1/28/26  
**Time:** 9:02 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 1/31/26  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/28/26	4:55 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/28/26	9:02 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/28/26	9:02 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/28/26	9:02 AM	GR	Visual

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)