



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 333

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Western PA School	Date:	9/9/25			
Address:	201 N. Bellefield Ave. Pittsburgh, PA 15213	Time:	10:35 AM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	9/12/25			
	Therapy Pool	Time:	10:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	9/10/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/10/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/9/25	2:30 PM	AS	SM 9215B

<u>Field Analysis</u>	<u>Results</u>	<u>Reporting limit</u>	<u>Date/Time</u>	<u>Analyst</u>	<u>Method</u>	
pH:	7.2 SU	7.2 - 7.8 SU	9/9/25	10:35 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/9/25	10:35 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/9/25	10:35 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor