



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2699

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/22/25
Time: 12:25 PM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Facility Name: Arabian Meadows
Address: 475 Barnickel St
Washington, PA 15301

Matrix: Recreational Water
Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/23/25 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/0/00 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/22/25 3:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/22/25 12:25 PM | GR | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/22/25 12:25 PM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 12:25 PM | GR | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2699

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/22/25
Time: 12:25 PM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Facility Name: Arabian Meadows
Address: 475 Barnickel St
Washington, PA 15301

Matrix: Recreational Water
Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/23/25 10:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/0/00 10:00 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/22/25 3:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|------------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/22/25 12:25 PM | GR | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/22/25 12:25 PM | GR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 12:25 PM | GR | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor