



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 154

Customer

Facility Name: Hilton Garden Inn
Address: 2000 Garden View
Cranberry, PA 16066
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 12/15/25
Time: 10:45 AM
Method: Grab

Sample Final Analysis

Date: 12/18/25
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/16/25 11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/16/25 11:00 AM	AS	SM 9222B
Standard plate count:	570/ml	200/ml	12/15/25 5:40 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/16/25 12:00 PM	AS	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 /SU	7.2 - 7.8 SU	12/15/25 10:45 AM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/15/25 10:45 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/15/25 10:45 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)