



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 033

Customer

Facility Name: Candlewood Suites
Address: 20036 Rt. 19, Oak Tree Place
Cranberry Twp., PA 16066

Sample Collection

Date: 6/23/25
Time: 10:07 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 6/26/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/23/25	10:07 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:07 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:07 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 033

Customer

Facility Name: Candlewood Suites
Address: 20036 Rt. 19, Oak Tree Place
Cranberry Twp., PA 16066

Sample Collection

Date: 6/23/25
Time: 10:07 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 6/26/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	3:24 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/23/25	10:07 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/25	10:07 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	10:07 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

Andre Smith

(When exceeding reporting limit pool or spa is unfit)