Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 415

Customer

Facility Name:	Drury Hotel
Address:	101 Ridge Rd. Pittsburgh, PA 15205
Matrix:	Recreational Water
Source Type:	Pool

Sample Collection

Date:	6/24/25
Time:	9:15 AM
Method:	Grab

Sample Final Analysis

Date:	6/27/25
Time:	9:20 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 415

Customer

Facility Name:	*Drury Hotel*
Address:	*101 Ridge Rd.*
	Pittsburgh, PA 15205
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/24/25*
Time:	*9:15 AM*
Method:	*Grab*

Sample Final Analysis

Date:	*6/27/25*
Time:	*9:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	3:10 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor