



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2504

Customer

Facility Name: *St Clair Country Club*

Address: *2300 Old Washington Rd.*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *6/24/25*
Time: *4:15 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/27/25*
Time: *9:20 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/25/25 | 12:00 PM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/25/25 | 12:00 PM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/24/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/24/25 | 4:15 PM | AF | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 6/24/25 | 4:15 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/24/25 | 4:15 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2504

Customer

Facility Name: *St Clair Country Club*

Address: *2300 Old Washington Rd.*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Collection

Date: *6/24/25*
Time: *4:15 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/27/25*
Time: *9:20 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/25/25 | 12:00 PM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/25/25 | 12:00 PM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/24/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/24/25 | 4:15 PM | AF | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 6/24/25 | 4:15 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/24/25 | 4:15 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor