



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 253

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/6/25*

Time: *3:25 PM*

Method: *Grab*

Sample Final Analysis

Date: *10/9/25*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/7/25	10:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	10/7/25	10:20 AM	AS	SM 9222B
Standard plate count:	0/ml	A	10/6/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	10/6/25	3:25 PM	MM	DPD
Chlorine:	3.0 mg/l	A	10/6/25	3:25 PM	MM	DPD
Turbidity:	1 NTU	A	10/6/25	3:25 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor