



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 414

Laboratory Analysis Report

Customer

Facility Name: Town Place Airport
Address: 1006 Sutherland Dr.
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 11/4/25
Time: 12:00 PM
Method: Grab

Sample Final Analysis

Date: 11/7/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|-----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 11/5/25 9:30 AM | SL | SM 9222G |
| Total coliforms: | 1/100mls | 2/100mls | 11/5/25 9:30 AM | SL | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 11/4/25 4:32 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 11/5/25 10:10 AM | SL | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|------------------|----|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 11/4/25 12:00 PM | VH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 11/4/25 12:00 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/4/25 12:00 PM | VH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor