



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E-3

Lab# 475

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Altoona HS	Date:	10/6/25		
Address:	1404 6th Ave Altoona, PA 16602	Time:	2:30 PM		
Matrix:		<u>Sample Final Analysis</u>			
Source Type:	Recreational Water	Date:	10/9/25		
	Pool	Time:	11:00 AM		
		Analyst:	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method

Escherichia Coli:	Absent	Absent	10/7/25	10:20 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/7/25	10:20 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	10/6/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	10/6/25	2:30 PM	DNP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	10/6/25	2:30 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/6/25	2:30 PM	DNP	Visual

Sample comments

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor