Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2623

Customer

Facility Name: *Washington Park*

Address: *283 Dunn Ave.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Collection

Date: *7/29/25*
Time: 9:40 AM
Method: *Grab*

Sample Final Analysis

Date: *8/1/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	9:40 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	9:40 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	9:40 AM	GR	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2623

Customer

Facility Name: *Washington Park*

Address: *283 Dunn Ave.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Collection

Date: *7/29/25*
Time: 9:40 AM
Method: *Grab*

Sample Final Analysis

Date: *8/1/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	9:40 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	9:40 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	9:40 AM	GR	Visual

Sample comments

Andrea Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor