



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:	Nineteen North Apts	<u>Sample Collection</u>
Address:	1050 Nineteen North Dr. Pittsburgh, PA 15237	Date: 8/11/25 Time: 10:56 AM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Pool	Date: 8/14/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/11/25	10:56 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:56 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:56 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name:	Nineteen North Apts	<u>Sample Collection</u>
Address:	1050 Nineteen North Dr. Pittsburgh, PA 15237	Date: 8/11/25 Time: 10:56 AM Method: Grab
Matrix:	Recreational Water	<u>Sample Final Analysis</u>
Source Type:	Pool	Date: 8/14/25 Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	8/11/25	10:56 AM	MM	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:56 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:56 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor