



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 375

Customer

Facility Name: Southside Works
Address: 2626 South Tunnel Blvd
Pittsburgh, PA 15203

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/12/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: #REF!

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	8/12/25	3:58 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/13/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	2:40 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	2:40 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	2:40 PM	LM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 375

Customer

Facility Name: Southside Works
Address: 2626 South Tunnel Blvd
Pittsburgh, PA 15203
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 8/12/25
Time: 2:40 PM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: #REF!

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	10:00 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	8/12/25	3:58 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/13/25	11:30 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/12/25	2:40 PM	LM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/12/25	2:40 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	2:40 PM	LM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor