



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 389

Customer

Facility Name: *Fairfield Inn & Suites*
Address: *1000 University Parkway*
Slippery Rock, PA 16057

Sample Collection

Date: *6/16/25*
Time: *2:30 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/19/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/16/25	2:30 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 389

Customer

Facility Name: *Fairfield Inn & Suites*
Address: *1000 University Parkway*
Slippery Rock, PA 16057

Sample Collection

Date: *6/16/25*
Time: *2:30 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/19/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/16/25	2:30 PM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:30 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:30 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor