



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2323**

**Customer**

Facility Name: Londonbury Homes

Address: 220 Downing Dr.  
Moon, PA 15108

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 7/15/25

Time: 12:15 PM

Method: Grab

**Sample Final Analysis**

Date: 7/18/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:01 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	12:15 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:15 PM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2323**

**Customer**

Facility Name: *Londonbury Homes*

Address: *220 Downing Dr.*  
*Moon, PA 15108*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *7/15/25*

Time: *12:15 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/18/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:01 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	12:15 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	12:15 PM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor