



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 324**

**Customer**

**Facility Name:** Verland Foundation  
**Address:** 212 Iris Rd.  
Sewickley, PA 15143

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Collection**

**Date:** 10/27/25  
**Time:** 10:34 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 10/30/25  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25 10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25 5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/27/25 10:34 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/27/25 10:34 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25 10:34 AM	AMH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor