



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 285

Customer

Facility Name: Springhill Suites
Address: 3015 Pittsburgh Mills Blvd.
Tarentum, PA 15084

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/6/26
Time: 10:24 AM
Method: Grab

Sample Final Analysis

Date: 1/9/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/7/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/7/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/6/26	4:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	1/6/26	10:24 AM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/6/26	10:24 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/6/26	10:24 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor