

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 2119

Customer Facility Name:

Club at Nevillewood

Address: 1000 Nevillewood Drive

Presto, PA 15142

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: 8/11/25

Time: 11:30 AM Method: Grab

Sample Final Analysis

8/14/25 Date:

Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 8/12/25 10:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 8/12/25 10:30 AM EB SM 9222B Standard plate count: 0/ml 200/ml 8/11/25 5:20 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|---------|--------|--|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/11/25 | 11:30 AM | AF | DPD | |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 11:30 AM | AF | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 11:30 AM | AF | Visual | |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

S-14

Lab ID No. 02-04041

Lab# 2119

Customer Facility Name:

Club at Nevillewood

Address: 1000 Nevillewood Drive

Presto, PA 15142

Recreational Water Matrix:

Source Type: Pool Sample Collection

Date: 8/11/25

Time: 11:30 AM Method: Grab

Sample Final Analysis

8/14/25 Date:

Time: 9:00 AM Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 8/12/25 10:30 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 8/12/25 10:30 AM EB SM 9222B Standard plate count: 0/ml 200/ml 8/11/25 5:20 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|---------|--------|--|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/11/25 | 11:30 AM | AF | DPD | |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 11:30 AM | AF | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 11:30 AM | AF | Visual | |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith