Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 415

Customer		**_Sample Collection_**
Facility Name:	*Drury Hotel*	*Date:* 7/29/25
		Time: 9:15 AM
Address:	*101 Ridge Rd.*	*Method:* *Grab*
	Pittsburgh, PA 15205	
		Sample Final Analysis
Matrix:	*Recreational Water*	*Date:* 8/1/25
		Time: 9:00 AM
Source Type:	*Pool*	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	3:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	9:15 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	9:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 415

Customer		**Sample Collection**	
Facility Name:	*Drury Hotel*	*Date:*	7/29/25
		Time:	9:15 AM
Address:	*101 Ridge Rd.*	*Method:*	*Grab*
	Pittsburgh, PA 15205		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/1/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	3:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	9:15 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/29/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	9:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor